NATIONAL CERT STANDARD

	CLASSIFICATION OF CERT PREMISES		MINIMUM TRAINING	MINIMUM EQUIPPING				BASIC TASKING
				PPE ¹	MITIGATION	FIRST AID	COMMUNICATION	DASIC TASKING
P&FM Premises	Tier 1 P&FM	Premises storing more than 5 metric tons of Petroleum & Flammable Material ³	WSQ Respond to Fire & Hazmat Emergency (3 days) CERT First Aider Couse (1 day)	 Chemical suits² Rubber gloves² Rubber boots² Firefighting suits Firefighting helmets Goggles / Face shields Firefighting gloves Firefighting boots Breathing apparatus 	 HazMat absorbents² Leak sealing devices² Overpack drums² Fire extinguishers (appropriate class) Firefighting nozzles hoses 		• Loud hailer • Walkie-talkie	 Contain HazMat leaks² Prevent spread of HazMat² & fires Activate HazMat² & fire protection systems Contain and mitigate incipient stages of HazMat² & fire incidents Perform first aid, CPR & use AED Implement In-Place Protection Conduct mass evacuation Assist emergency responders
Premises	Tier 1 HRI	Public & Industrial premises with FSM <u>and</u> classified as High Risk Installations by SCDF	WSQ Respond to Fire Emergency in Buildings (2 days)	 Fire retardant coveralls Safety helmets Goggles / Face shields Safety gloves Safety boots Breathing apparatus Fire retardant coveralls Safety helmets Goggles / Face shields Safety gloves Safety boots 	Fire extinguishers (appropriate class)	 First aid kit Foldable stretcher Blanket AED 		 Contain and mitigate incipient stages of fire incidents Perform first aid, CPR & use AED Implement In-Place Protection Conduct mass evacuation Assist emergency responders
ty Manager	Tie	Public & Industrial premises with FSM and storing 5 or less metric tons of P&FM ²	CERT First Aider Couse (1 day)					
Fire Safety	Tier 3	Public & Industrial premises with FSM	WSQ Respond to Fire Incident in Workplace (1 day) CERT First Aider Couse (1 day)					

¹ A minimum of 5 sets of PPE are required, for 1 SIC and 4 ERT members. ² If applicable.

³ Diesel is excluded from the P&FMs quantity for the purpose of CERT tier classification. For premises with no other P&FM storage and are not HRIs, premises with underground diesel storage tanks will be in tier 3 and premises with aboveground diesel storage tanks will be in tier 2. LPG storage for food stalls is also excluded from the P&FM quantity for the purpose of CERT tier classification. These provisions may not be applicable to all premises.